RESIDENTIAL & COMMERCIAL FIRE PUMP SPECIALISTS
6040 NE 112TH AVE. PORTLAND, OR 97220

800-878-8055 WWW.TALCOFIRE.COM

HOME HYDRANT


NFPA-13D Packaged Residential Fire Pump & Tank

U.S. Patents #8,678,032 & 8,905,069

HH3-150C

350 Gallon Water Tank

- 1 Tank Drain ½"(GHT)
- 2 Overflow Fitting 1"(NPT)
- 3 Auto-Fill Valve 3/4" (NPT
- 1.5HP Electric Motor240 Volt Single-Phase8.1 Amp (Full Load)
- 1 ½" Discharge (NPT)
 Smart Riser Control System
- (4) Isolation Ball Valve
- (5) Test Line/System Drain
- 6 Pressure Gauge
- The state of the s
- **8** Pressure Switch
- 10 Discharge Check Valve
- (11) Suction Shut-off Valve



Performance

Performance values based on multiple pump tests. Not for certification purposes

			Total marie value based on maripho pamp teste. Not for estamoured purposees.				
GPM	0	20	25	30	35	40	45
PSI	47	45	44	43	41	40	39